

ADDENDUM



OWNER

WEST OTTAWA PUBLIC SCHOOLS

PROJECT

**SOUTH HIGH SCHOOL – PARTIAL ROOF
REPLACEMENT**

A/E Project 5-4876

PURPOSE

ADDENDUM 001
THIS ADDENDUM SHALL FORM PART OF THE
BIDDING DOCUMENTS. CHANGES, ADDITIONS,
CLARIFICATIONS OR DELETIONS HEREIN
SUPERSEDE THE DRAWINGS AND
SPECIFICATIONS. BIDDERS SHALL INCLUDE ON
THE PROPOSAL FORM ACKNOWLEDGEMENT OF
THE RECEIPT OF THIS ADDENDUM.

ATTACHMENTS

New Specifications: 07 53 23
Reissued Specifications: 00 11 13, 00 41 00

New Sheets: None
Reissued Sheets: None

ARCHITECT-ENGINEER

GMB
www.gmb.com
616.796.0200

SPECIFICATION CLARIFICATIONS / REVISIONS

ITEM NO. 1 SECTION 00 11 13 - NOTICE TO BIDDERS (REISSUED)

Note revisions to revise the bid date to April 14, 2020 and that the pre-bid will be held VIRTUALLY on Zoom.

ITEM NO. 2 SECTION 00 41 00 - PROPOSAL FORM (REISSUED)

Note revisions to revise the bid date to April 14, 2020 and align the West Ottawa Public Schools contact with the Notice to Bidders.

ITEM NO. 3 SPECIFICATION 07 53 23 – ETHYLENE-PROPYLENE-DIENE-MONOMER (EPDM) ROOFING (REISSUED)

See spec for revision to heading 2.2 / subheading B. EPDM sheet for ballasted roofing areas to non-reinforced 60 mil.